


A SECTION A-A



B SECTION B-B

1 PIPE ROUTE LAYOUT

SUCTION PIPING LIQUID PIPING DIAL TYPE TEMPERATURE INDICATOR DISPLAY -MOUNTED AT EYE LEVEL, WITH TEMPERATURE PROBE MOUNTED INSIDE SUITABLE OIL POT IN THE ROOM. TT TEMPERATURE TRANSMITTER H D S DEFROST HEATER & SAFETY THERMOSTAT BY REFRIGERATION CONTRACTOR SAFETY THERMOSTAT BY REFRIGERATION CONTRACTOR ELECTRICAL & CONTROL DB/MCC SUPPLIED AND INSTALLED BY REFRIGERATION CONTRACTOR CONTROL DB FOR EVAPORATOR CONTROLLERS BY REFRIGERATION SUBCONTRACTOR HARD WIRED ALARM BOARD BY REFRIGERATION CONTRACTOR AS SPECIFIED REFRIGERATION MONITORING SYSTEM BY BY REFRIGERATION CONTRACTOR TRAPPED PERSONNEL ALARM PUSH BUTTON BY REFRIGERATION CONTRACTOR FIELD WIRING FOR TPA BY REFRIGERATION CONTRACTOR TRAPPED PERSONELL ALARM (AUDIO & VISUAL) AS SPECIFIED EQUIPMENT TO BE MOUNTED ON SUITABLE ANTI-VIBRATION MOUNTINGS OR TICO PADS VS VALVE STATION EVAPORATOR COIL PIPE DROP PIPE RISE HMI HUMAN MACHINE INTERFACE FOR TENDER AMC ENGINEERS

198 Buitengracht St, Cape
Town City Centre, Cape
Town, 8000 ISIOLO KENYA MECHANICAL SERVICE: REFRIGERATION PIPE ROUTE LAYOUT SCALE AT A0: As indicated 07/05/21 PROJECT NO: 1200  $\textbf{D}: DRAFT \ / \ \textbf{P}: PRELIMINARY \ / \ \textbf{E}: COUNCIL \ / \ \textbf{T}: TENDER \ / \ \textbf{F}: FINAL \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{X}: CANCELLED \ / \ \textbf{C}: CONSTRUCTION \ / \ \textbf{A}: AS-BUILT, RECORD \ / \ \textbf{A}: AS-BUILT,$ 

This document and its content are confidential and copyrighted. It may not be disclosed or

NOTES

ASSOCIATED ELECTRICAL AND CONTROL WIRING BY REFRIGERATION CONTRACTOR TO BE SUPPORTED OFF THE SAME TRAPEZE HANGERS AND TO FOLLOW THE PIPE ROUTES.

**LEGENDS** 

RAG - CURVED BLADE RETURN AIR GRILL (HINGED) COMPLETE WITH PLENUM BOX AND FILTER MEDIA. SIZE AS PER

BD - BALANCING DAMPERS COMPLETE WITH LOCKING QUADRANTS

CONTRACTOR. INTEGRAL OR SEPARATE TO UNIT
HWC - HARD WIRED CONTROLLER ATTACHED TO THE WALL WITH
BRACKET BY AC CONTRACTOR.
IRC - INFRA RED CONTROLLER ATTACHED TO THE WALL WITH

SAD - SUPPLY AIR DIFFUSER SIZE AS INDICATED EAG - EXTRACT AIR GRILLE SIZE AS INDICATED

WMS - WIRE MESH SCREEN TO BE FITTED ON ALL

BRACKET BY AC CONTRACTOR.
TAG - TRANSFER AIR GRILLE
SA - SOUND ATTENUATOR SIZE AS INDICATED

SAG - SUPPLY AIR GRILLE SIZE AS INDICATED

CP - CONDENSATE PUMP PROVIDED WITH UNIT BY AC

OBD - OPPOSED BLADE DAMPER

AHU - AIR HANDLING UNIT

NRD - NON RETURN DAMPER

EF - EXTRACT AIR FAN FF - FRESH AIR FAN PFB - PLEATED FILTER BANK

LOUVRES FD - FIRE DAMPER

reproduced without express authorisation from AMC Engineers CC.

TENDER PURPOSES ONLY

REVISION: